



Product Alert

January 5, 2018

Type of Notification: Misrepresentation of FM Approved Product

FM Approvals has been notified by Metron Eledyne, Div. of Hubbell Inc of a concern involving Diesel Fire Pump Controllers which have been misrepresented as FM Approved.

Company Identity: Metron Eledyne, Div. of Hubbell Inc.
Gai-Tronics

Address: Stretton Business Park, Brunel Drive,
Burton-on-Trent, Staffs. DE13 0BZ, UK

Contact information: General Enquiries: +44 (0) 1283 500 500

Product Identity: Diesel Fire Pump Controllers.

Models: EFP/a/b/FD4e/c marked with the following serial numbers:

198210-01, 198210-02, 208320-01, 208320-02, 225310-01, 225310-02,
225310-03, 229150-01, 229150-02, 208600-01 & 208600-02.

FM Approval Status: Not FM Approved.

Hazard Involved: The products identified have been confirmed to have been manufactured and labelled as FM Approved without certification to FM Approval standards.

If you suspect you are in possession of any of the affected equipment listed above bearing the FM Approvals certification marking, please bring that to the attention of:

Antonio L. Pires
FM Approvals, Quality Department
Norwood, MA, USA
+1 (1)781 255 4825
Email: Antonio.pires@fmapprovals.com