



Product Alert – Counterfeit Clarke Fire Protection Products – Fire Pump Diesel Drivers

October 17th, 2023

Type of Notification: Counterfeit

FM Approvals has been made aware of counterfeit Clarke Fire Protection Products found in Mexico bearing the FM Approvals mark. FM Approvals has neither tested nor certified these products.

Company Identity: Clarke Fire Protection Products Inc
Address: 100 Progress Place, Cincinnati, Ohio

Company Identity: Clarke Fire Protection Products Ltd
Address: Unit 1 Grange Works, Lomond Road, Coatbridge, United Kingdom

Contact Information: Customer Support at parts@clarkefire.com
Tel No. (513) 475-3473 (US) or 44-1236-429-946 (UK)

Product Identity: Clarke Fire Protection Products – Fire Pump Diesel Drivers

FM Approval Status: Not FM Approved

Hazard Involved: There have been reports of counterfeit Fire Pump Drivers and Fire Pumps that are being counterfeited in Mexico. Clarke has also reported forged and altered nameplates in other parts of the world. The source of these suspected counterfeit products has not been identified.

If you suspect you are in possession of a counterfeit fire pump driver or pump bearing the FM Approvals certification mark or if you have any information relative to these referenced products, please bring that to the attention of:

Antonio L. Pires
FM Approvals, Quality Department
Norwood, MA, USA
+1 (1)781 255 4825
Email: antonio.pires@fmapprovals.com



Figure 1. Photograph of the suspected counterfeit nameplate. A valid Clarke Fire Protection Products' nameplate would have the FM Approvals certification mark and a QR code present. It would not have a reference to CNP NM Fire Fighting System Co., Ltd at the bottom.



Figure 2. Photograph of an actual Clarke Fire Protection Products nameplate with a QR code. The QR code links to a Clarke Fire Protection Products website where a user can validate a product's data.