FM Approvals

Product Alert

Date: June 26, 2025

Honeywell Analytics Limited, Searchpoint Optima Plus Gas Detector – Product Safety Concern

FM Approvals has been notified by Honeywell Analytics Limited that Searchpoint Optima Plus gas detectors produced between January 13, 2025, and February 14, 2025, were assembled with the glass window improperly pressed into the holder.

Type of Notification: Product Safety Notification

Company Identity: Honeywell Analytics Limited, Hatchpond House, Nuffield Industrial Estate, 4 Stinsford Rd, Poole, Dorset BH17 ORZ, United Kingdom

Product Identity: Searchpoint Optima Plus gas detectors

FM Approval Status: FM Approved

Hazard Involved: FM Approvals has been notified by Honeywell Analytics Limited that Searchpoint Optima Plus gas detectors produced between January 13, 2025, and February 14, 2025, and identified with serial numbers between Z0177025030001 and Z0177125080617, were assembled with the glass window improperly pressed into the holder. The improper assembly may result in chipping or cracking of the glass window which may impact the Hazardous Location rating of the product.

In the event that you are in possession of a gas detector within this serial number range and have not been contacted by Honeywell, please contact the Honeywell support team at https://sps-support.honeywell.com/s/hgas.

Antonio L. Pires
FM Approvals, Quality Assurance

Norwood, MA, USA
+1 (1)781 255 4825
Email: antonio.pires@fmapprovals.com